

S- 35
TRIPLEX

S.C.C.R. 5000A

SUNBELT™
POWER CONTROLS
 1625 Wallace Dr, Ste 100
 Carrollton, Texas 75006
 (972) 620-2950
 info@sunbeltpowercontrols.com
 sunbeltpowercontrols.com

DATE 11/15/07

HP. _____

DRAWING# S333HW

VOLT. _____

DRAWN BY RAK

PHASE 3

SERIAL # _____

FLA _____

**NOTE (USE COPPER, 60 C RATED WIRE FOR LESS THAN 100A
 USE COPPER, 75 C RATED WIRE FOR 100A OR MORE)**

CAUTION:
 AN N.E.C. APPROVED BRANCH
 CIRCUIT PROTECTIVE DEVICE
 MUST BE INSTALLED AHEAD
 OF THIS CONTROL PANEL IN
 ACCORDANCE WITH THE N.E.C.

